

<b>Parameter</b>	<b>INFINITY</b>	<b>WHO Limits</b>
pH @ 25°	8 - 9	6,5 - 9,5
Conductivity @ 25°	22 - 71,2	Not Applicable
Total Dissolved Solid (TDS)	14 - 50	max 1000
Colour	<5	max 15
Turbidity	0,25 - 0,31	max 5
Hardness	8,63 - 9	Not Applicable
Odour	Acceptable	Acceptable
Chloride	0 - 0,2	250
Sulphate	Not Detected	max 250
Nitrates	Not Detected	max 50
Fluorides	Not Detected	max 1,5
Alkalinity	7,5 - 10	Not Applicable
Calcium	3 - 6	Not Applicable
Magnesium	0,5 - 1,92	Not Applicable
Manganese	<1	Not Applicable
Iron	Not Detected	max 200
Copper	Not Detected	max 20
Nickel	Not Detected	max 20
Zinc	Not Detected	max 3
Coliform	Not Detected	<1
Enterococci	Not Detected	0
E. Coli	Not Detected	0
Heterotrophic plate count	Not Detected	22°C/37°C 100/20
Pseudomonas aeruginosa	Not Detected	0
Clostridium perfringens	Not Detected	0